

## SUMMARY OF COOLING TOWER TESTING STATUS

Build- ing No.	CT No.	Location	Last Sampling Date	Test	Status
3A	40	Administration - Roof Area 3A	9 May 2012	HCC & Leg	Clear
5	43	Krongold Centre S. Roof Plant Room	2 May 2012	HCC & Leg	Clear
11S	51	Humanities South- 9th floor unit 1	2 May 2012	HCC & Leg	Clear
11S	56	Humanities South- 9th floor unit 2	2 May 2012	HCC & Leg	Clear
12	37	Law School - Roof Area	2 May 2012	HCC & Leg	Clear
13F	31/32	Medical 13F Roof Plant Rm	2 May 2012	HCC & Leg	Clear
13D	34/35	Medical 13D South Roof	2 May 2012	HCC & Leg	Clear
15	55	Sch. of Medical & Health Sciences Roof	2 May 2012	HCC & Leg	Clear
17	29	Biology - Roof Area	2 May 2012	HCC & Leg	Clear
18	25	Zoology East - Roof Area	2 May 2012		System Empty
18	26	Zoology West - Roof Area	2 May 2012	HCC & Leg	Clear
19	20	Physics Roof Near Building 26	2 May 2012	HCC & Leg	Clear
23	21	Chemistry - South West Roof	2 May 2012	HCC & Leg	Clear
23	23	Chemistry East Roof Area	2 May 2012	HCC & Leg	Clear
23	24	Chemistry East Roof Area	2 May 2012		System Empty
23	58	Chemistry East Roof Area	2 May 2012	HCC & Leg	Clear
23	59	Chemistry East Roof Area	2 May 2012	HCC & Leg	Clear
25	49/50	Eastern Science Lecture Theatres	2 May 2012	HCC & Leg	Clear
27	15	Physics North-West Roof	2 May 2012	HCC & Leg	Clear
27	17	Physics South-West Tower Area	2 May 2012	HCC & Leg	Clear
28	9/10	Mathematics Building Ground North	2 May 2012	HCC & Leg	Clear
30	08	Hargrave-Andrew Library Roof	2 May 2012	HCC & Leg	Clear
35	57	Engineering 35 West Roof	2 May 2012	HCC & Leg	Clear
36	06	Engineering 36 West Roof	2 May 2012	HCC & Leg	Clear
36	07	Engineering 36 East Roof	2 May 2012	HCC & Leg	Clear
37	05	Engineering 37 South East Roof	2 May 2012	HCC & Leg	Clear
37	01	North Ground - Engineering 37	2 May 2012	HCC & Leg	Clear
55	48	The Gallery Compound	2 May 2012	HCC & Leg	Clear
68	46/47	Performing Arts Centre - East Roof	2 May 2012	HCC & Leg	Clear
75	52/53	STRIP 1 Building 75 Roof	2 May 2012	HCC & Leg	Clear
75	54	STRIP 1 Building 75 Roof	2 May 2012	HCC & Leg	Clear
76	60/ 61	STRIP 2 Building 76 Roof	2 May 2012	HCC & Leg	Clear

If the status of a cooling tower is defined as 'Not Clear' please contact Jerry Donovan (9902 0086) or Peter Mather (9905 3040) before a Roof Access Permit is issued.